

DECLARATION OF TEST RESULTS

No. 18896D

Non-loadbearing sandwich panel partition wall
type: **REX SDW WALL 1150** – thickness: 100 mm

The element is fully described in test report No. 18896A and classified in classification report No. 18896C.

Obtained test results:

Parameters	Results
Thermal insulation – I	36 minutes
Integrity – E	72 minutes
Radiation – W	72 minutes

Extension of span length (= height)

Until a classification of E 60 and EW 60, the span (= height) of the partition (panel to panel stitching c/c 300 mm) may be increased up to 6 m. Until a classification of E 30 and EW 30, the span (=height) of the partition (panel to panel stitching c/c 300 mm) may be increased up to 7.5 m.

Until a classification of EI 30, the span (= height) of the partition (panel to panel stitching c/c 300 mm) may be increased up to 4 m. Until a classification of EI 20, the span (=height) of the partition (panel to panel stitching c/c 300 mm) may be increased up to 7.5 m.

This declaration is valid until: 31 July 2021.

WFRGENT NV

European classifications can only be proved with the official classification report No. 18896C according to EN 13501-2.

This document may be used only literally and completely for publications. - For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance. The authenticity of the electronic signatures is assured by Belgium Root CA.